

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 21/2026

Dated: 6-5-2026

It is certified that an inspection team headed by

REENA MT. HEALTH INSPECTOR (Name of Officers with designation)

from Family Health Centre Puthupadi PHED

inspected the Mar Baselios English Medium School Engapuzha

(Name & Address of the school) on 6-5-2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. 7324/2026/04

dated 02-05-2026 of CWRDM Kozhikode (PHED Lab)

certified that the


Marbaselios English Medium (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 6-5-2027



Signature with Seal:

Name

REENA MT

Designation

HEALTH INSPECTOR

Name & Address of the Office / Department:

FAMILY HEALTH CENTRE PUTHUPADI

HEALTH INSPECTOR
PRIMARY HEALTH CENTRE
PUTHUPADI

Marbaselios English
Medium School Engapuzha, Kozhikode (District)
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Principal

Principal
Mar Baselios English Medium School
Engapuzha, Calicut - 673 586
CBSE Affiliation No: 930338



KSCSTE - CENTRE FOR WATER RESOURCES DEVELOPMENT AND MANAGEMENT

ജലവിഭവ വികസന വിനിയോഗ കേന്ദ്രം

(An ISO 9001 : 2015 Certified Organization)

An Institution of Kerala State Council for Science, Technology & Environment, Govt. of Kerala
കേരള ശാസ്ത്ര സാങ്കേതിക പരിസ്ഥിതി കൗൺസിൽ സ്ഥാപനം, കേരള സർക്കാർ



CWRDM WATER QUALITY DIVISION-TESTING LABORATORY TEST REPORT

No: CWRDM/WQD/WA/7324/2026

ULR - TC124082600000940F

Customer Name and Address: Mar Baselios English Medium School C/O. Shaju Engapuzha	Date of Issue :02-05-2026 Date of receipt of sample :20-04-2026 SRF No :7324/2026 Test Report No :7324/2026/04 Analysis Started :20-04-2026 Analysis Completed :25-04-2026
Information Provided by Customer: Sample Source Sample Type Volume of Sample Supplied Sample Drawn By	Borewell Drinking Water 1L Party

TEST RESULTS-CHEMICAL ANALYSIS

Sl. No.	Parameters	Test Method	Result	Acceptable limit as per IS 10500:2012
1	pH at 25°C	APHA, 2023 (Part 4500 II- B)	6.66	6.50-8.50
2	Colour, Hazen	APHA, 2023 (Part 2120 B)	<1.0	5.0
3	Turbidity, NTU	APHA, 2023 (Part 2130 B)	0.20	1.0
4	Total Dissolved Solids, mg/l	APHA, 2023 (Part 2540 C)	50.0	500.0
5	Total Hardness as CaCO ₃ , mg/l	APHA, 2023 (Part 2340 C)	28.0	200.0
6	Total Alkalinity as CaCO ₃ , mg/l	APHA, 2023 (Part 2320 B)	20.0	200.0
7	Chloride as Cl ⁻ , mg/l	APHA, 2023 (Part 4500 Cl- B)	12.0	250.0
8	Sulphate as SO ₄ ²⁻ , mg/l	APHA, 2023 (Part 4500 SO ₄ ²⁻ E)	4.20	200.0
9	Calcium as Ca, mg/l	APHA, 2023 (Part 3500 Ca B)	8.0	75.0
10	Magnesium as Mg, mg/l	APHA, 2023 (Part 3500 Mg B)	1.90	30.0
11	Iron as Fe, mg/l	APHA, 2023 (Part 3500 Fe B)	BDL	1.0

BDL-Below Detection Limit

Detection limit of Iron is 0.2mg/l

Note: -

All the tested water quality parameters are found to be within the acceptable limit as per IS 10500:2012, Drinking Water Specification.

*****End of the Report*****

For CWRDM, Water Quality Division - Testing Laboratory

Tested by *[Signature]*

Authorised & Reviewed by *[Signature]*

Note: This test report refers only to the particular item(s) submitted for testing. The test results obtained in this report are valid at the time of and under the stated condition of measurement. This particular test report cannot be reproduced without the permission of the Head of Water Quality Division of the laboratory. Any discrepancies may be brought to the laboratory.

TECHNICAL MANAGER
CWRDM WATER QUALITY DIVISION
TESTING LABORATORY

Kunnamangalam, Kozhikode-673571, Kerala, India കുന്നമംഗലം, കോഴിക്കോട്-673571, കേരളം, ഇന്ത്യ

E-mail: ed@cwrmdm.org, registrar@cwrmdm.org Website: www.cwrmdm.kerala.gov.in

Phone: (91) 495 235 1800, 235 1801

WATER QUALITY DIVISION

CENTRE FOR WATER RESOURCES DEVELOPMENT AND MANAGEMENT KOZHIKODE-673571

No: CWRDM/WQD/WA/7324/2026N

Customer Name and Address: Mar Baselios English Medium School C/O. Shaju Engapuzha	Date of Issue :02-05-2026 Date of receipt of sample :20-04-2026 SRF No :7324/2026 Test Report No :7324/2026/04 Analysis Started :20-04-2026 Analysis Completed :21-04-2026
Information Provided by Customer: Sample Source Sample Type Volume of Sample Supplied Sample Drawn By	Borewell Drinking Water 1L Party

TEST RESULTS - BACTERIOLOGICAL ANALYSIS

Sl. No.	Parameters	Test Method	Result	Acceptable limit as per IS 10500:2012
1	Total Coliforms, CFU/100ml	APHA, 2023(Part 9222 B)	Present (79)	Shall not be detectable in any 100ml sample
2	<i>E. coli</i> , CFU/100ml	APHA, 2023(Part 9222 G)	Absent	Shall not be detectable in any 100ml sample

Note: -

The water sample is contaminated with Total Coliforms.

*****End of the Report*****

For CWRDM, Water Quality Division – Testing Laboratory

Tested by
[Signature]

Authorised & Reviewed by
[Signature]
Dr. Shaju M.

Note: This test report refers only to the particular item(s) submitted for testing. The test results reported in this report are valid at the time of and under the stated condition of measurement. This particular test report cannot be reproduced except in full, without prior permission of Head – Water Quality Division of the laboratory. Any discrepancies may be brought to the laboratory within 30 days of the date of the report.

TESTING LABORATORY



Principal
Mar Baselios English Medium School
Engapuzha, Calicut - 673 586
CBSE Affiliation No: 930338

[Signature]